

Issues from Mulah, Madifushi and Kinbidhoo Pre Bid Meeting

1. Length of cable to Mulah IWMC. If it is 600 meters there might be additional distribution box for voltage drop: **Main cable laying removed from scope.**
2. How many seats for Joali: **Removed from scope**
3. Size of table at staff area: **Removed from scope**
4. IWMC Location map for each island: **Please refer to Annex 1**
5. Vegetation information

5.1. M. Mulah

Type	Amount	Approximate Size (length)	Protected
Coconut Palm (Large)	15	50 ft	No
Coconut Palm (Medium)	10	30 – 40 ft	No
Mature Trees (Feyru, Helenbeli, Kaani)	15	25 – 30 ft	No

5.2. Th. Kinbidhoo

Type	Amount	Approximate Size (length)	Protected
Coconut Palm (Large)	70	50 ft	No

5.3. Th. Madifushi

Vegetation not present at the site.

6. What to do with removed trees?: **Piled and left in the periphery for natural degeneration. Larger tree trunks and branches, etc. shall be chopped to a reasonable size and left at the periphery or burnt after acquiring permission from the council. Alternatively, the removed trees can be reused by the contractor after discussing with the council.**
7. Bid Security period: **90 Days from the date of Bid Submission.**
8. Septic tank for toilet : **Additional septic tank for toilet to be included in scope of works. Find attached drawing and revised BoQ.**
9. Bid Submission Date:

M. Mulah – 21 June 2018 – 1030hrs

Th. Kinbidhoo - 21 June 2018 – 1100hrs

Th. Madifushi – 21 June 2018 – 1130hrs