



بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ބޭނުން ޖަހާ ފަރާތްތަކުގެ ޖެނެރަލް ޕްރޮޓެކްޝަން ޔުޅުމާލު
Environmental Protection Agency



Table 4: Annual Tests

The following parameters must be tested once every year along with those given in Table 1, Table 2 and Table 3.

Parameter	Reference range
Anionic detergents	0.002 - 0.275 mg/l
Arsenic	<0.01 mg/l
Boron	<0.3 mg/l
Bromine	0.05 – 4.50 mg/l
Cadmium	<0.003 mg/l
Calcium hardness	<60 mg/l
Chromium	<0.05 mg/l
Copper	<2 mg/l
Cyanide	<0.07 mg/l
Enterococci	0/100ml CFU
Fluoride	<1.5 mg/l
Lead	<0.01 mg/l
Manganese	0.1 mg/l
Mercury	<0.001 mg/l
Phenolic compounds	0.002 - 0.2 mg/l
Phosphate	<5mg/l
Potassium	0 – 50 mg/l
Salmonella Typhi	0/100ml CFU
Shigella spp.	0/100ml CFU
Sodium	<200 mg/l
Sulphate	<250 mg/l
Total petroleum hydrocarbon	0 mg/l
Vibrio Cholerae	0/100ml CFU